Fire Protection Checklist							
Location/Department:	Date of	Date of Inspection:					
Inspectors:	1						
Corrective Actions: Work order/memos were issued: Yes No The following safety and health checklist is based on the MIOSHA		Date issued: standards. It may not include <i>all</i>					
conditions, as it is intended to be used only as a guide.							
Topic Description	Yes	No	N/A	Comments			
Is your local fire department well-acquainted with your facility, its location, and specific hazards?							
Do you have a fire alarm system, and is it certified as required?							
Do you have a fire alarm system, and is it tested at least annually?							
Do you have interior stand pipes and valves; are they inspected regularly?							
Do you have outside private fire hydrants; are they flushed at least once a year and on a routine preventive maintenance schedule?							
Are fire doors and shutters in good operating condition?							
Are fire doors and shutters unobstructed and protected against obstructions, including their counterweights?							
Are fire door and shutter fusible links in place?							
Are automatic sprinkler system water control valves and air and water pressure checked weekly/periodically as required?							
Is the maintenance of automatic sprinkler systems assigned to responsible persons or to a sprinkler contractor?							
Are sprinkler heads protected by metal guards when exposed to physical damage?							
Is proper clearance maintained below sprinkler heads?							
Are portable fire extinguishers provided in adequate number and type?							
Are fire extinguishers mounted in readily accessible locations?							



Fire Protection Checklist (continued)					
Topic Description	Yes	No	N/A	Comments	
Are fire extinguishers recharged regularly and noted on the inspection tag?					
Are employees periodically instructed in the use of extinguishers and fire protection procedures?					

